

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well:		County CLOUD	Fraction SE 1/4 NE 1/4 NW 1/4	Section number 33	Township number T 5	Range number R 2	E (W)
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:				
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>32</u> in. Completion date <u>12-23-76</u> Well depth <u>58</u> ft.				
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
5. Type and color of material			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material <u>AC</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>34</u> lbs./ft. Dia. <u>16</u> in. to <u>58</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gauge No. <u>34</u>				
			10. Screen: Manufacturer's name <u>JOHNSON</u> <u>CONCRETE</u> Type <u>TRANSITE</u> Dia. <u>16</u> Slot/gauze <u>1/8"</u> Length <u>26</u> Set between <u>32</u> ft. and <u>58</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>YES</u> Size range of material <u>3/8-1/4"</u>				
			11. Static water level: <u>10</u> ft. below land surface ma./day/yr. Date <u>12-13-76</u>				
			12. Pumping level below land surfaces: <u>16</u> ft. after <u>1/2</u> hrs. pumping <u>900</u> g.p.m. <u>18</u> ft. after <u>1/2</u> hrs. pumping <u>1200</u> g.p.m. Estimated maximum yield <u>2000</u> g.p.m.				
			13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>				
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade				
			15. Well grouted? <u>YES</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.				
			16. Nearest source of possible contamination: <u> </u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
			(Use a second sheet if needed)				
18. Elevation: <u>1370</u>		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>GEO COX + SONS, INC 258</u> Business name <u>CLIFTON KANS</u> License No. <u> </u> Address <u> </u> Signed <u>Francis Cox</u> Date <u>12-29</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5