

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Cloud	Fraction NW 1/4 SW 1/4 NE 1/4	Section number 35	Township number T 5 S R 2 E W	Range number	
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:				
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 32 in. Completion date 11-12-77 Well depth 85 ft.				
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
5. Type and color of material			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material AC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 16 in. to 85 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 34				
			10. Screen: Manufacturer's name Johnson Concrete Type transite Dia. 16 Slot/groove 1/8 Length 26 Set between 59 ft. and 85 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/2-1/4				
			11. Static water level: <input type="checkbox"/> mo./day/yr. 25 ft. below land surface Date 5-21-77				
			12. Pumping level below land surfaces: 54 ft. after 1 hrs. pumping 1250 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 2000 g.p.m.				
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>				
			14. Well head completion: <input type="checkbox"/> Pitless adapter 24 inches above grade				
			15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				
			16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WLR Model number 10B HP 70 Volts <input type="checkbox"/> Length of drop pipe 76 ft. capacity 1500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
18. Elevation: 1320'		19. Remarks: 		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name Joe Cox + Sons Inc License No. 258 Address Clifton, Kansas Signed Francis Cox Date 11-2-77 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

5-2-77
 R
 W
 Sec
 35
 1/4 1/4 1/4
 WILSONE