

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Norton	Section SW 1/4	Section number 23	Township number T 5 S	Range number R 23 W
2. Distance and direction from nearest town or city: Street address of well location if in city:		2 west 2 south of Edmond Kansas				
3. Owner of well: R.R. or street:		Wymann Delp Edmond Kansas 67636				
Locate with "X" in section below: Sketch map:		6. Bore hole dia. 9 in. Completion date 8/27/79 Well depth 39 ft.				
7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
9. Casing: Material Plas Height: Above 0 Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 225 lbs./ft. Dia. 0 in. to 29 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 258		10. Screen: Manufacturer's name Malvern Pipe Inc. Type PVC Dia. 5" Slot 0.32 Length 10' Set between 29 ft. and 39 ft. Gravel pack? Yes Size range of material 1/8 to 1/4				
5. Type and color of material		From	To	11. Static water level: 7 ft. below land surface Date 8/16/79		
Clay & Lime Rock		0	26	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 10 g.p.m.		
Sand		26	37	13. Water sample submitted: ____ Yes <input checked="" type="checkbox"/> No Date ____		
Shale		37	39	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12" Inches above grade		
BRICK 37' thick				15. Well grouted? Yes With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
30' sat thick				16. Nearest source of possible contamination: ft. 120 Direction west Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No		
in Og				17. Pump: Manufacturer's name Aeromotor Not installed Model number SD8-33 HP 3 Volts 220 Length of drop pipe 28 ft. capacity 8 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Fawcett & Son Dr. 167 Business name License No. Address Norton Kansas Signed John R. Fawcett Date 9/25/79 Authorized representative		