


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County NORTON	Township name LENORA	Fraction SW 1/4 SE-SW	Section number 11	Town number 5	Range number 24
Distance and direction from nearest town or city: IN 1/2 W				3 Owner of well: ALLAN DAY			
Street address of well location if in city: LENORA				Address: LENORA			
Locate with "X" in section below:		Sketch map:		4 Well depth: 30 ft. Date of completion 4-5-78 Well diameter 8 in.			
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
				7 Casing: Material STEEL Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 5 in. to 30 ft. depth Weight 150 lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No			
2		Type and color of material		From	To	8 Screen:	
		CLAY		0	20	Manufacturer JTL	
		SAND & G		20	24	Type 510T Dia. 5"	
		CLAY		24	26	Slot/gauze 20 Length 6	
		SAND & GRAVEL		26	29	Set between 30 ft. and 24 ft.	
		SHALE BLUE		29	30	Fittings:	
						Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/16	
		BROCK				9 Static water level:	
		29'				24 ft. below land surface Date 4-5-78	
		24				10 Pumping level below land surfaces:	
		5' sat H.C.				____ ft. after ____ hrs. pumping ____ g.p.m.	
		2310				____ ft. after ____ hrs. pumping ____ g.p.m.	
		225'				Estimated maximum yield ____ g.p.m.	
		1208				11 Water sample submitted:	
						<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
						12 Well head completion:	
						<input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						<input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/>	
						Depth: From 11 ft. to 0 ft.	
						14 Nearest source of possible contamination:	
						ft. ____ Direction ____ Type ____	
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						15 Pump:	
						<input checked="" type="checkbox"/> Not installed	
						Manufacturer's name ____	
						Model number ____ HP ____ Volts ____	
						Length of drop pipe ____ ft. capacity ____ g.p.m.	
						Type:	
						<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation				17 Water well contractor's certification:			
2310				This well was drilled under my jurisdiction and this			
NATIVE GRASS				report is true to the best of my knowledge and belief.			
PASTURE				DARREL MINIMUM 240			
Topography:				Business name			
<input checked="" type="checkbox"/> Hill				Address NORLAND KS License No. ____			
<input checked="" type="checkbox"/> Slope				Signed [Signature] Date 4-5-78			
<input type="checkbox"/> Upland				Authorized representative			
<input type="checkbox"/> Valley							