

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DDU

1. Location of well: County Decatur Fraction SW 1/4 SE 1/4 SE 1/4 Section number 12 Township number T 5 S R 29 E W

2. Distance and direction from nearest town or city: SW 1/2 N Dresden 3. Owner of well: Morre Brothers
Street address of well location if in city: R.R. or street:
City, state, zip code: Dresden, Ks.

4. Locate with "X" in section below: Sketch map:
N
W E
S
1 Mile
1 Mile

6. Bore hole dia. 27 in. Completion date 7/29/75
Well depth 47 ft.
7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary
8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other
9. Casing: Material Asbc Height: Above or below
Threaded Welded Surface 48 in.
RMP PVC Weight 38.46 lbs./ft.
Dia 16 in. to 20 ft. depth Wall Thickness inches or
Dia 16 in. to ft. depth gage No. 23

5. Type and color of material	From	To
<u>Top soil</u>	<u>0</u>	<u>14</u>
<u>sand</u>	<u>14</u>	<u>22</u>
<u>clay</u>	<u>22</u>	<u>23</u>
<u>sand</u>	<u>23</u>	<u>29</u>
<u>sand + clay</u>	<u>29</u>	<u>32</u>
<u>sand</u>	<u>32</u>	<u>45</u>
<u>shale</u>	<u>45</u>	<u>47</u>
<u>2665'</u>		
<u>Casing was left 5' above the surrounding surface. The customer saw cement at 4' x 4' x 1/2' and then pushed soil up to 6" of the top of the cement</u>		
(Use a second sheet if needed)		

10. Screen: Manufacturer's name John Manswell
Type Asb-C Dia. 16'
Slot/gauge 2.8 Length 27'
Set between 20 ft. and 47 ft.
_____ ft. and _____ ft.
Gravel pack? yes Size range of material 1/4
11. Static water level: _____ mo./day/yr.
17 ft. below land surface Date 4/14/75
12. Pumping level below land surfaces:
32 ft. after 4 hrs. pumping 300 g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 325 g.p.m.
13. Water sample submitted: _____ mo./day/yr.
Yes No Date _____

14. Well head completion:
 Pitless adapter 60 inches above grade
15. Well grouted? yes
With: Neat cement Bentonite Concrete
Depth: From _____ ft. to _____ ft.
16. Nearest source of possible contamination:
ft. 200 Direction N Type River
Well disinfected upon completion? Yes No
17. Pump: Not installed
Manufacturer's name Western Drill
Model number 25 HP 25 Volts 140
Length of drop pipe 50 ft. capacity 300 g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: Topography: Hill Slope Upland Valley
19. Remarks: 2665' (TOP)

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Corder Drilling 114
Business name _____ License No. _____
Address Selden, Ks.
Signed Clare Corder Date 12-10-75
Authorized representative

T 5
R 49
E 1
Sec 12
SW SE SE
1/4 1/4 1/4