USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Decatur	SW 1/4 SW 1/4 SW 1/4	34	T 5 S	R 29 E (W)

2. Distance and direction from nearest town or city: 6 W 15 Leoville

Street address of well location if in city:

3. Owner of well: Hillcrest Farms, Inc.
R.R. or street:
City, state, zip code: Selden, Ks

4. Locate with "X" in section below: Sketch map:

N — NW — NE — W — E — SW — SE — S — 1 Mile — 1 Mile

6. Bore hole dia. 7 in. Completion date 5/20/75
Well depth 185 ft.

7. __ Cable tool ✓ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: ✓ Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material RMP Height: (Above) or below
Threaded ___ Welded ___ Surface 2 in.
RMP ✓ PVC ___ Weight 1.81 lbs./ft.
Dia. 5 in. to 165 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 250

5. Type and color of material	From	To
Top soil	0	80
sand	80	84
clay	84	85
sand	85	120
sand + clay	120	126
rock	126	130
sand	130	156
sandstone	156	159
sand	159	172
sand + clay	172	175
sand	175	185
shale	185	

(Use a second sheet if needed)

10. Screen: Manufacturer's name Jess + Lowell Superior
Type RMP Dia. 5"
Slot/gauze 1/32 Length 20'
Set between 165 ft. and 185 ft.
___ ft. and ___ ft.
Gravel pack? ~~yes~~ Size range of material 1/32

11. Static water level: mo./day/yr.
128 ft. below land surface Date 11/15/75

12. Pumping level below land surfaces: Not tested
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
___ Yes ✓ No Date ___

14. Well head completion:
___ Pitless adapter 6 Inches above grade

15. Well grouted? ~~yes~~ clay
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 0 ft. to 20 ft.

16. Nearest source of possible contamination:
ft. 150 Direction S Type Ditch
Well disinfected upon completion? ✓ Yes ___ No

17. Pump: ✓ Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.p.m.
Type:
___ Submersible ___ Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

T 5 R 29 (W) Sec 34 SW SW SW 1/4

18. Elevation:
Topography:
___ Hill
✓ Slope
___ Upland
___ Valley

19. Remarks: 1st. cement plug cement 1½
2nd clay
3rd cement clay 15
2765' (TOPO)
Cement plug 4
20

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Corder Drilling 114
Business name License No.
Address Selden, Ks
Signed Elmer Corder Date 12-10-75
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5