


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County Rawlins	Township name R0VOHL 4E	Fraction SE 1/4 of SW 1/4	Section number 34	Town number 5	Range number 33
Distance and direction from nearest town or city: 16 miles South 2 1/2 E Street address of well location if in city: from Atwood				3 Owner of well: Allen R Pence Address: Colby, Kansas			
Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		4 Well depth: 224 ft. Date of completion 3-18-75 Well diameter 28 in.			
2 Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
						7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Digm. 16 in. to 154 ft. depth 7 gauge 16 Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
						8 Screen: Manufacturer W. A. Brown Type bridge Dia. 16" Slot/gauze 178 Length 2" Set between 154 ft. and 214 ft. Fittings: 10' Cook -- 214-224 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 x 1/2	
						9 Static water level: 140 ft. below land surface Date 3-20-75	
Clay with sand layers		0		130		10 Pumping level below land surfaces: 210 ft. after 2 hrs. pumping 600 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 600 g.p.m.	
Cemented sand		130		132		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
Fine to coarse sand & gravel with clay lenses		132		161		12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
Fine to coarse sand & gravel		161		174		13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite & clay Depth: From 0 ft. to 10 ft.	
Sandy clay		174		176		14 Nearest source of possible contamination: ft. 1/2 mile Direction North Type unknown Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Fine to coarse sand & gravel		176		183		15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Byron Jackson Model number ____ HP 85 Volts ____ Length of drop pipe 210 ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Cemented sand		183		185		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump Inc. 245 Business name P.O. Box 852, Colby, KS. Address Ray F. Denning Date May 20 1975 Signed Ray F. Denning Authorized representative	
Fine to coarse sand & gravel		185		191			
Sandy clay		191		198			
Fine to coarse sand & gravel few clay lenses		198		206			
Fine to coarse sand & gravel		206		221			
Shale		221		224			
(use a second sheet if needed)							
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley 3147							