

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Rawlins	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 29	Township number T 5 S	Range number R 35 E
2. Distance and direction from nearest town or city: Levant, KS 14 1/2 miles North; 3 1/4 miles West Street address of well location if in city:				3. Owner of well: Howard Gene Curry R.R. or street: City, state, zip code: Levant, KS 67743		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:				6. Bore hole dia. 36 in. Completion date 10-22-78 Well depth 280 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.75 lbs./ft. Dia. 16 in. to 280 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188 10. Screen: Manufacturer's name Cook Type Wire Wrapped Dia. 16 Slot/gauze 100 Length 10 Set between 270 ft. and 280 ft. Perf (Brown) 190 and 270 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 30% #1-70 1/4 x 5/8 11. Static water level: 151 ft. below land surface Date 10-16-78 mo./day/yr. 12. Pumping level below land surfaces: 275 ft. after 2 hrs. pumping 636 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 636 g.p.m. 13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr. 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade 15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: ft. 3000 Direction WSW Type Farmstead Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number 10DOM HP 100 Volts <input type="checkbox"/> Length of drop pipe 276 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245 Business name License No. Address Box 852 Colby, KS 67701 Signed OD On the way Date 11/7/78 Authorized Representative		
5. Type and color of material				From	To	
Top Soil, Clay, & Gravel Streaks				0	160	
Fine Sand & Sandstone (Layers, Hard)				160	170	
Fine Sand & Streaks Sandstone				170	181	
Fine Sand & Trace Clay				181	205	
Sandstone & Clay (Hard)				205	210	
Fine Sand & Sandstone				210	220	
Fine Sand & Medium Gravel (Brown, Loose)				220	256	
Sandstone				256	257	
Fine Sand & Medium Gravel (Brown, Loose)				256	270	
Medium Gravel (Loose)				270	278	
Ochre & Shale				278	290	
BROCK 278'						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						