

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Cloud	Fraction 1/4 NW 1/4	Section number 1	Township number T 5 S R 4	Range number 4 NW
2. Distance and direction from nearest town or city: Street address of well location if in city:		3. Owner of well: R.R. or street: City, state, zip code:		4 north Concordia street South side of road Lynn Helbert R.R. #3 Concordia, KS 66901		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 5 in. Completion date June 15 1975 Well depth 92 ft.		
		no Building Feature		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		1	30	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 72 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1/4 in		
Clay		30	60	10. Screen: Manufacturer's name Western Type plastic Dia. 5 in Slot/gauze 1/4 in Length 10 ft Set between 1/4 in ft. and 92 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 in		
Top soil		1	45	11. Static water level: _____ mo./day/yr. 50 ft. below land surface Date 6/12/75		
SAND STONE		45	92	12. Pumping level below land surfaces: 70 ft. after 5 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 1 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ hp _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation: 1470'	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name Gene Thomas License No. _____ Address Concordia, KS 66901 Signed Gene Thomas Date 6/15/75 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5