

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County @bud	Fraction 1/4 SW 1/4 NE 1/4	Section number 23	Township number T 5 S R 4 R/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:		1/4 mi. West of Concordia, MO CONCORDIA, MO		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 5 in. Completion date 12/23/77 Well depth 33 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Black-grey soil		0	2	9. Casing: Material _____ Height: <input checked="" type="checkbox"/> Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 33 ft. depth! Wall thickness: inches or Dia. _____ in. to _____ ft. depth! gage No. 1/4		
fine sand		3	11	10. Screen: Manufacturer's name CAN-FLEX Type 160 Dia. 5 in Slot/gauze 3/16 Length 10 Set between 23 ft. and 33 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4		
redish gravel		12	22	11. Static water level: _____ mg./day/yr. 18 ft. below land surface Date 12/23/77		
Grey Course Gravel		23	33	12. Pumping level below land surfaces: 22 ft. after 3 hrs. pumping 12 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
				13. Water sample submitted: _____ mg./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 12/23/77		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 14 inches above grade		
				15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
				16. Nearest source of possible contamination: ft. 400 Direction E Type COYACK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name MILBY Model number 2205-4B Volts 230 Length of drop pipe 24 ft. capacity 14 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1370'		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CARL THOMAS 247 Business name Carl Thomas License No. _____ Address 212 E. 1st St. Concordia, MO Signed Carl Thomas Date 12/23/77		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5