


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: <u>Cloud</u>		Fraction: <u>1/4 SE 1/4</u>	Section number: <u>3</u>	Township number: <u>T 6 S R 1 E/W</u>	Range number: <u>1</u>
2. Distance and direction from nearest town or city: <u>3 miles South of Clyde Kansas</u>			3. Owner of well: <u>Francis Odette</u> R.R. or street: <u>Rt #1</u> City, state, zip code: <u>Clyde, Kansas 66938</u>		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. <u>8</u> in. Completion date: <u>Aug. 11, 1976</u> Well depth <u>135</u> ft.	
5. Type and color of material		From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hallaw rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface <u>12</u> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>135</u> ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth Gage No. <u>14</u>	
				10. Screen: Manufacturer's name <u>Vetstream</u> Type <u>1/64</u> Dia. <u>5</u> " Slat/gauze <u>1/64</u> Length <u>20 ft.</u> Set between <u>1 1/2</u> ft. and <u>1 3/5</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4</u>	
				11. Static water level: _____ mo./day/yr. <u>100</u> ft. below land surface Date <u>Aug. 13, 1976</u>	
				12. Pumping level below land surfaces: <u>100</u> ft. after <u>4</u> hrs. pumping <u>10</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>10</u> g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>Aug. 13, 1976</u>	
				14. Well head completion: _____ <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade	
				15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>1</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination: _____ <u>250</u> Direction <u>North</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name <u>Red Jacket</u> Model number <u>100 RT</u> HP <u>1 HP</u> Volts <u>220</u> Length of drop pipe <u>110</u> ft. capacity <u>15</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation: <u>1338</u> Topography: _____ <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Carl Thomas Ford 247</u> Business name <u>333 E 16th Concordia KS</u> License No. _____ <u>Carl Thomas</u> Date <u>08/13 1976</u> Authorized representative	

T  
R  
1  
W  
3  
S  
E  
1/4  
1/4  
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5