

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

? NE SW NE

1. Location of well: County CLOUD		Fraction NW 1/4 ^{W 1/2 of} 1/4 1/4		Section number 5	Township number T 6 S R 1 W E/W	Range number
2. Distance and direction from nearest town or city: 1/2 S & 1/4 WEST OF AMES, KANSAS				3. Owner of well: WILLIAM CZAPANSKIY R.R. or street: R.R. City, state, zip code: CLYDE, KANSAS 66938		
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile				6. Bore hole dia ^{3 3/4} 16 1/2 in. Completion date 6-15-78 Well depth 162 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
CLAY				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
HARD SAND ROCK				9. Casing: Material CONCRETE Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 72 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia 16 in. to 16 1/2 ft. depth Wall Thickness: inches or Dio. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 2"		
MEDIUM COARSE SAND ROCK				10. Screen: Manufacturer's name SILVER CREEK PIPE & SUPPLY Type CONCRETE Dia. 16 Slot/gauze 80' Length 80' Set between 160' ft. and 80' ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material ROAD GRAVEL		
GRAVEL				11. Static water level: <input type="checkbox"/> mo./day/yr. 56 ft. below land surface Date 6/19/78		
SHALE				12. Pumping level below land surfaces: 85 ft. after 2 hrs. pumping 885 g.p.m. 89 ft. after 2 hrs. pumping 1000 g.p.m. Estimated maximum yield 1250+ g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				<input checked="" type="checkbox"/> Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 9 ft. to 2 ft.		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name FAIRBANKS MORSE Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GROSCH IRRIGATION 367 Business name SILVER CREEK, NEB. License No. 1/4 1/8 1/4 Address 1/2 200 Signed Kenneth J. Speed Date 7-19-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5