

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA:82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County GRAHAM	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 2	Township number T 6 S R 23 E/W	Range number 23
2. Distance and direction from nearest town or city: 4.800000 miles west of Edmond, Ks.			3. Owner of well: ALFONSO SCHUECK R.R. Edmond, Ks. 67636			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 4/28/79 Well depth 165 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
CLAY & SAND		0	25	9. Casing: Material PLASTIC Height: Above or below Threading Welded Surface 24 in. RMP PVC <input checked="" type="checkbox"/> Weight 165 lbs./ft. Dia 5 in. to 165 ft. depth Wall Thickness: inches or Dia. in. to ft. depth Gage No. 250		
Rock		25	33	10. Screen: Manufacturer's name Jet STREAM Type PLASTIC Dia. 5" Slot/gauze 4/6 Length 10' Set between 165 ft. and 165 ft. Gravel pack? yes Size range of material 1/4-5/8"		
SAND, ROCK & clay STRIPS		33	110	11. Static water level: 92 ft. below land surface Date 4/28/79 mo./day/yr.		
Fine SAND with CLAY AND ROCK STRIPS		110	147	12. Pumping level below land surfaces: NOT PUMPED ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Rock.		147	167	13. Water sample submitted: NO mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
BROCK ?				14. Well head completion: NOT done Pitless adapter _____ Inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: access ft. 100 Direction NORTH Type pool Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D&L Drilling Co 309 Business name License No. Bx 368 Hill City, Ks. 67642 Address Signed Alfonso Schueck Date 5/24/79 Authorized representative		
19. Remarks: CUSTOMER TO INSTALL CEMENT SLAB AT GROUND level						
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						