USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

AAB

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County	Fraction	Section number	Township number	Range number
Graham	NW 1/4 NE 1/4 NE 1/4	26	T 6 S	R 24 E/W

2. Distance and direction from nearest town or city: Penokee, Kansas
11 mi. North; 3/4 mi. East
Street address of well location if in city:

3. Owner of well: Carl Striggow
R.R. or street:
City, state, zip code: Hill City, Kansas 67642

4. Locate with "X" in section below: Sketch map:

N — NW — NE — W — E — SW — SE — S — 1 Mile — 1 Mile

6. Bore hole dia. 30 in. Completion date
Well depth 148 ft. 2/1/79

7. __ Cable tool __ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored X Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Steel Height: Above or below
Threaded ___ Welded X Surface 12 in.
RMP ___ PVC ___ Weight 3425 lbs./ft.
Dia. 16 in. to 148 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. .204

5. Type and color of material	From	To
Clay	0	30
Gravel	30	53
Clay	53	70
Sandstone	70	80
Clay	80	91
Coarse sand, medium gravel	91	110
Clay	110	111
Fine to Coarse sand	111	136
Clay	136	138
Coarse Sand 144	138	143
Rock 43 101' set the well	143	144
Ochre & Shale in Og	144	160
BROCK 144'		
IN APP# 30,765		
(Use a second sheet if needed)		

10. Screen: Manufacturer's name Cook
Type Wire wrapped Dia. 16
Slot/gauze 100 Length 10
Set between 138 ft. and 148 ft.
Brown Perf 74 ft. and 134 ft.
Gravel pack? ___ Size range of material 50%#1, 50% 3/4x5/8

11. Static water level: mo./day/yr.
43 ft. below land surface Date 2/2/79

12. Pumping level below land surfaces:
97 ft. after 1 hrs. pumping 805 g.p.m.
91 ft. after 1 hrs. pumping 599 g.p.m.
Estimated maximum yield 943 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date

14. Well head completion:
__ Pitless adapter 48 Inches above grade

15. Well grouted? yes
With: __ Neat cement __ Bentonite X Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 1,700 Direction ENE Type Farmstead
Well disinfected upon completion? ___ Yes X No

17. Pump: __ Not installed
Manufacturer's name Floway
Model number 10DOH HP 79 Volts -
Length of drop pipe [redacted] 147 ft. capacity 700 g.p.m.
Type:
__ Submersible X Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

T 6 S R 24 E/W Sec 26 1/4 NW NE NE 1/4

18. Elevation:
Topography:
X Hill
__ Slope
__ Upland
__ Valley

19. Remarks:
2405 Not TM Topo
144
2261

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Western Well & Pump License No. 245
Address P.O.Box 852, Colby, Kansas
Signed O.D. Calhoon Date 2-19-79
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5