



USE TYPEWRITER OR BALL POINT PEN-PRESS FAMILY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Cloud		Fraction 5 acre plot 1/4 1/4 1/4		Section number 21		Township number 6 T S R		Range number 3 E/W			
2. Distance and direction from nearest town or city: 3 miles south of Concordia 1/4 mi west North side of road.				3. Owner of well: LYNN L. POWELL R.R. or street: 1004 STATE ST. City, state, zip code: CONCORDIA, KANSAS 66901							
4. Locate with "X" in section below: 				Sketch map: 		6. Bore hole dia. 8 in. Completion date: Nov. 16, 1976 Well depth 90 ft.					
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary							
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other							
5. Type and color of material				From		To		9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 24 in. RMP 5" PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 90 ft. depth Wall Thickness _____ inches or Dio. _____ in. to _____ ft. depth gage No. 14			
Black soil				0		9		10. Screen: Manufacturer's name CAN-TEX Type 160/164 Dio. 5" Slot/gauze 1/64 Length 20' Set between 70 ft. and 90 ft. _____ ft. and _____ ft.			
Sand stone				10		75		Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"			
CLAY				76		80		11. Static water level: _____ mo./day/yr. 25 ft. below land surface Date Nov. 17, 1976			
Sand stone				81		90		12. Pumping level below land surfaces: 70 ft. after 2 hrs. pumping 12 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15 g.p.m.			
								13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 11/20/76			
								14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade			
								15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From 1 ft. to 10 ft.			
								16. Nearest source of possible contamination: ft. 300 ft. North Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
								17. Pump: _____ Not installed Manufacturer's name Meters Model S-2-B HP 1/2 Volts 220 Length of drop pipe 80 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation: ~1480		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Thomas 247 Business name 16th & Concordia KS License No. _____ Address _____ Signed Carl Thomas Date 12/20/76 Authorized representative							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5