

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Cloud	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 5	Township number T 6 S	Range number R 4 E
2. Distance and direction from nearest town or city: X WEST 1/2 N of JAMESON Street address of well location if in city: Jameson 3rd St 2 North			3. Owner of well: DUDLEY THURSTON R.R. or street: RT. City, state, zip code: CONCORDIA, KANSAS		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: BCB		
5. Type and color of material			From	To	6. Bore hole dia. 32 in. Completion date Well depth 103 ft. 7-6-78
CLAY			0	25	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
BLUE CLAY			25	33	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
SAND			33	34	9. Casing: Material CONCRETE Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 I.D. ft. depth Wall Thickness: inches or Dia. TOP TO BOTTOM ft. depth gage No. _____
CLAY			34	36	10. Screen: Manufacturer's name SILVER CREEK PIPE & SUPPLY Type CONCRETE Dia. 16" I.D. Slot/gauze _____ Length _____ Set between 40 ft. and 103 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material ROAD GRAVEL
SAND & CLAY LAYERS			36	45	11. Static water level: _____ mo./day/yr. 33 ft. below land surface Date _____
SAND & CLAY LAYERS			45	105	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. 100 ft. after 6 hrs. pumping 75 g.p.m. Estimated maximum yield 75 g.p.m.
ROCK			105	115	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 7-7-78
SHALE			115	135	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
					15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 12 ft. to GROUND LEVEL
					16. <input checked="" type="checkbox"/> NOTHING surface of visible contamination THE Direction AREA Type _____ Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Branch Description 367 Business name Fishers Creek, Topeka License No. _____ Address Kenneth Road Signed Kenneth Road Date 12-6-78 Authorized representative
18. Elevation: 21420	19. Remarks: CONCORDIA				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

1-5
 NW 1/4 SW 1/4 NW 1/4
 Sec 5
 T 6 S
 R 4 E