

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Cloud	Fraction NE 1/4 SE 1/4 SE 1/4	Section number 24	Township number T 6 S 4 E W	Range number 4
2. Distance and direction from nearest town or city: 4 1/2 - 2 1/2 W			3. Owner of well: Ralph Ball			
Street address of well location if in city: of Concordia			R.R. or street: #1			
			City, state, zip code: Concordia, Ka 66901			
4. Locate with "X" in section below:			Sketch map:			6. Bore hole dia. 26 in. Completion date 7-13-78
			Well depth 201 ft.			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
			5. Type and color of material			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
			9. Casing: Material AC Height: Above or below			9. Casing: Material AC Height: Above or below
			Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in.			Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in.
			RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft.			RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft.
			Dia. 16 in. to 20 ft. depth Wall Thickness: inches or			Dia. 16 in. to 20 ft. depth Wall Thickness: inches or
			Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth page No. 3/4			Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth page No. 3/4
			10. Screen: Manufacturer's name Johnson Casing			10. Screen: Manufacturer's name Johnson Casing
			Type transite Dia. 16			Type transite Dia. 16
			Slot/gauge 1/8 Length 39			Slot/gauge 1/8 Length 39
			Set between 162 ft. and 201 ft.			Set between 162 ft. and 201 ft.
			Gravel pack? YES Size range of material 1/4-1/4			Gravel pack? YES Size range of material 1/4-1/4
			11. Static water level: 80 ft. below land surface Date 7-13-78			11. Static water level: 80 ft. below land surface Date 7-13-78
			12. Pumping level below land surfaces: 195 ft. after 4 hrs. pumping 450 g.p.m.			12. Pumping level below land surfaces: 195 ft. after 4 hrs. pumping 450 g.p.m.
			Estimated maximum yield 450 g.p.m.			Estimated maximum yield 450 g.p.m.
			13. Water sample submitted: X No Date			13. Water sample submitted: X No Date
			14. Well head completion: 12 inches above grade			14. Well head completion: 12 inches above grade
			15. Well grouted? YES			15. Well grouted? YES
			With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete			With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete
			Depth: From 0 ft. to 10 ft.			Depth: From 0 ft. to 10 ft.
			16. Nearest source of possible contamination: NONE			16. Nearest source of possible contamination: NONE
			Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
			17. Pump: WLR Not installed			17. Pump: WLR Not installed
			Manufacturer's name WLR			Manufacturer's name WLR
			Model number 6M HP 60 Volts 480			Model number 6M HP 60 Volts 480
			Length of drop pipe 198 ft. capacity 450 g.p.m.			Length of drop pipe 198 ft. capacity 450 g.p.m.
			Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine			Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine
			<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating			<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
			<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: ~1465		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Slope				Business name Cox-Beswick ICo. License No. 361		
<input type="checkbox"/> Upland		Address Clifton Kansas 66901			Signed Francis Cox Date 7-24	
<input type="checkbox"/> Valley					Authorized representative	

T-10-4-W-24-NE-SE
 Sec 24
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5