## REVISED - WELL LOCATED IN WRONG & ON FIRST REPORT USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT\CLEARLY. Kansas Department of Health and WATER WELL RECORD Environment-Division of Environment KSA 82a-1201-1215 (Water well Contractors) Topeka, Kansas 66620 Township number Range number County Fraction 1. Location of well: Sherman Boll, Merlyn 3. Owner of well: 2. Distance and direction from nearest town or city: From Kanorado; 13 3/4 North; ½ East Street address of well location if in city: City, state, zip code: Kanorado, Kansas 6. Bore hole dia. 36 in. Completion date 8-16Well depth 278 ft. 4. Locate with "X" in section below: Sketch map: 7. \_\_ Cable tool \_\_ Rotary \_\_ Driven . \_\_ Hollow rod \_\_ Jetted \_\_ Bored NE --8. Use: \_\_\_ Domestic \_\_\_ Public supply \_\_\_ Industry w X Irrigation \_\_\_ Air conditioning \_\_\_ Stock Lawn \_ Oil field water \_\_\_ 9. Casing: Material Steel Height: Above of BENEW Threaded \_\_\_\_ Welded X Surface \_\_ RMP\_\_\_\_\_PVC \_\_\_\_\_Weight \_\_.188\_lbs./ft Dia 16 in. to 188. depth Wall Thickness inches or - 1 Mile Dia. \_\_\_ in. to \_\_\_\_ ft. depth gage No. \_ 5. Type and color of material 10. Screen: Manufacturer's name \_ Brown 0 65 Type REgular Clay \_ Dia.\_ 801 Slot/gauze <u>10%</u> \_ Length \_ 65 113 Coarse Sand, Gravel, Clay Set between \_ 268 ft. and \_ 10 Cook 113 125 Gravel pack? X Size range of material 2x5/830%#1 Coarse Sand, Gravel 11. Static water level: mo./day/yr 125 130 Clay Clay 167 ft. below land surface Date 12. Pumping level below land surfaces: 130 Coarse Sand, Gravel \_\_ft.after \_ \_ hrs. pumping 276 ft. after 2 \_\_ hrs. pumping <u>578</u> g.p.m. 137 165 Clay, Sand Streaks Estimated maximum yield — 165 171 Sand, Gravel, Sand Stone 13. Water sample submitted: mo./day/yr Yes X No 177 171 Clay 14. Well head completion: Pitless adapter Inches above grade 177 184 mCoarse Sand, Gravel 15. Well grouted? X With:\_\_\_\_ Neat cement \_\_\_X\_\_ Bentonite \_ 184 191 Clay, Cemented Depth: From \_\_\_\_\_ ft. to \_\_\_\_ ft. 191 210 16. Nearest source of possible contamination: Clay, Cemented, Sand Stone Streaks ft. 2000 Direction N Type House Well disinfected upon completion? \_\_\_ 210 230 Med. Coarse Sand, Gravel, Sand Stone \_\_ Not installed Floway 232 230 Manufacturer's name Clay Model number <u>056178</u> HP <u>80</u> Length of drop pipe \_\_\_\_\_\_\_ ft. capacity \_\_\_\_ 261 232 Fine to Coarse Sand Type:12 Stage 10" DKM 261 273 Med. Coarse Sand, Samll Gravel X\_\_ Turbine \_\_\_\_ Submersible \_\_ Jet \_ Reciprocating (Use a second sheet if neede 273 278 Ochre, Shale Centrifugal 18. Elevation: 19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Topography: <u>Western Well & Pump</u> \_ Hill Address Box 852 Slope $\overline{\mathrm{X}}$ Upland Valley Forward the white, blue and pink copies to the Department of Health and Environment