

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Osborne	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 21	Township number T 7 S R 12 E/W	Range number
2. Distance and direction from nearest town or city: 1 1/4 south 2 miles East			3. Owner of well: Loyd C. Bloomer			
Street address of well location if in city: OS OSBORNE			R.R. or street: 202 W. MAIN			
			City, state, zip code: OSBORNE, KS, 67473			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 8/10/78		
				Well depth 55 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material TRANSITE Height: Above or below Threaded Banded Surface 6 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30 lbs./ft. Dia. 16 in. to 55 ft. depth Wall thickness, inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7811		
5. Type and color of material		From	To	10. Screen: Manufacturer's name JOHNSON CASING CO.		
CLAY		0	34	Type TRANSITE Dia. 16"		
SAND		34	40	Slot/gauze 3/16 Length 26'		
MUD		40	44	Set between 29 ft. and 55 ft.		
SAND		44	54	Gravel pack? Yes Size range of material 4-5/8		
SHALE		54	55	11. Static water level: 28 ft. below land surface Date 8/10/78		
				12. Pumping level below land surfaces: 53 ft. after 4 hrs. pumping 400 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 400 g.p.m.		
				13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter ____ Inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 1400 Direction West Type CRACK Well disinfected upon completion? ____ Yes ____ No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D & L DRILLING CO. 303 Business name HILL CITY License No. KA 95, 17642 Address BOX 368 HILL CITY, MO 64601 Signed Alford J. Jamin Date 8/10/78 Authorized representative				

7-12021-SUNNIE
1/4 1/4 1/4