

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County OSBORNE	Fraction SE 1/4 NE 1/4 NE 1/4	Section number 7	Township number T 7 S	Range number R 14 E/W
2. Distance and direction from nearest town or city: 2 E and 1/4 mile south Street address of well location if in city: AITON, Ks.				3. Owner of well: Cecil Bloomer R.R. or street: KAN FARMS INC. City, state, zip code: OSBORNE, Ks. 67473		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28" in. Completion date 10/31/77 Well depth 48 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				9. Casing: Material C/A Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 15 lbs./ft. Dia. 16 in. to 48 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 34"		
				10. Screen: Manufacturer's name JOHNSON CASING Type CONCRETE Dia. 16" Slot/gauze 3/16" Length 391 Set between 9 ft. and 48 ft. Gravel pack? YES Size range of material 4/16-5/8		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 11 ft. below land surface Date 10/13/77		
				12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. 48 ft. after 2 hrs. pumping 450 g.p.m. Estimated maximum yield 450 MAX. g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: FARM ft. 1/2 mile Direction west Type POND Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D. & L. DRILLING Co 303 Business name 8x368 License No. _____ Address HILL CITY, Ks. 67642 Signed Alford J. Jamin Date 10-24 Authorized Representative		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		19. Remarks: Concrete slab to be installed by customer at ground level.				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

7-14
 W
 7-SE 1/4 NE 1/4
 Sec 7-14-14