

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WCCERNE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ADD

1. Location of well:		County GRAHAM	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 7	Township number T 7 S R 25 E (W)	Range number 25
2. Distance and direction from nearest town or city: 3 WEST 5 NORTH, 3 WEST OF MORLAND, KS.			3. Owner of well: MRS. LEON SUPER R.R. or street: 320 S Middle City, state, zip code: Hill City, Ks, 67642			
4. Locate with "X" in section below:		Sketch map: PASTURE 150' O well CREEK			6. Bore hole dia. 9 in. Completion date: 3/31/79 Well depth 190 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material plastic Height: Above or below Threading glued Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 190 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1250	
					10. Screen: Manufacturer's name CROWN LINE Type plastic Dia. 5" Slot/gauze 1/16 Length 10' Set between 180 ft. and 190 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 4-5/8	
					11. Static water level: 87 no./day/yr. 87 ft. below land surface Date 3/31/79	
					12. Pumping level below land surfaces: NOT done _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
					14. Well head completion: NO <input type="checkbox"/> Pitless adapter _____ Inches above grade	
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: Creek ft. 150 Direction WEST Type Bed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks: CONCRETE slab to be installed by customer. 2522			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D.L. Drilling Co 303 Business name _____ License No. _____ Address 368 Hill City, Ks, 67642 Signed Allen J. [Signature] Date 4-19-79 Authorized representative	

7-2522-2 SESENE