

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

HOXIE NW

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

AAB

1. Location of well:		County SACRIDA N	Fraction NW 1/4 NE 1/4 NE 1/4	Section number 20	Township number T 7 S R 28	Range number 28	
2. Distance and direction from nearest town or city: Street address of well location if in city: HOXIE 6 N 1 1/4 W			3. Owner of well: MRT, Fred, Max & Tom Moss R.R. or street: City, state, zip code: Hoxie Kansas 67740				
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			6. Bore hole dia. 2 3/8 in. Completion date: 10-24-78 Well depth 232 ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Top Soil			0	3	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy Clay			3	45	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia 1 1/2 in. to 1 3/4 in. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
M Gravel			45	77	10. Screen: Manufacturer's name W. H. Brown Type LAUER Dia. 1 1/2 Slot/gauze 1/8 Length 70 Set between 162 ft. and 232 ft. Gravel pack? YES Size range of material 1/4 x 3/8		
Sandy Clay			77	79	11. Static water level: <input type="checkbox"/> mo./day/yr. 135 ft. below land surface Date 11-5-78		
M, Gravel, Sandy Clay			79	131	12. Pumping level below land surfaces: 28.5 ft. after 5 hrs. pumping 1250 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 1950 g.p.m.		
Sandy Clay, Sandstone			131	158	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
M Gravel			158	165	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Sandy Clay			165	167	15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
M Gravel			167	199	16. Nearest source of possible contamination: ft. _____ Direction _____ Type None Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Sandy Clay			199	208	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Packer Model number 84 HP 100 Volts 280 Length of drop pipe 220 ft. capacity 1250 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
M Gravel			208	226	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bill Duffing Co Inc 166 Business name _____ License No. _____ Address Goodland Kansas Signed Bill Clifford Date 10-24-78 Authorized representative		
Ochre			226	232			
BROCK 226							
(Use a second sheet if needed)							
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 2781 (TOPO)					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5