


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County SHERIDAN	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 1	Township number T 7 S R 29 E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:	8 N 3 1/2 W of Hope		3. Owner of well: M. H. French R.R. or street: 345 Bruce Drive City, state, zip code: Lincoln Neb		
4. Locate with "X" in section below: N W E S 1 Mile	Sketch map: 		6. Bore hole dia. 20 in. Completion date 9-22-76 Well depth 380 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Top Soil	0	135	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Thin sand M gravel sandy clay	135	155	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 1 3/4 to 2 3/4 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 179		
loose colored	155	165	10. Screen: Manufacturer's name WA Brown Type LUVAK Dia. 12 3/4 Slot/gauze _____ Length _____ Set between 200 ft. and 380 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4 x 3/8		
sandy clay	165	175	11. Static water level: _____ mo./day/yr. 161 ft. below land surface Date 9-22-76		
sandy clay sand stone	175	215	12. Pumping level below land surfaces: 155 ft. after 3 hrs. pumping 800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1000 g.p.m.		
M Gravel sandy clay	229	235	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
land	235	240	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
loose	240	245	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
loose	252	255	16. Nearest source of possible contamination: ft. _____ Direction _____ Type NONE Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
loose colored	265	274	17. Pump: _____ Not installed Manufacturer's name GOULDS Model number 8112 HP _____ Volts _____ Length of drop pipe 270 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Ocher shale	274	315			
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Blue Jay Drilling Co Inc 214 Business name _____ License No. _____ Address Box 503 Chiles Mo Signed Marilyn Kall Date 11-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T-2
 R-29
 E-1
 Sec 1-SESESW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5