

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

*Hand corrected
7-16-79
D.D.C.*

1. Location of well:		County Sheridan	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 12	Township number T 7 S	Range number R 29 E/W
2. Distance and direction from nearest town or city: Hoxie, Kansas 4 mi. West; 6 1/2 mi. North Street address of well location if in city:				3. Owner of well: David Schamberger R.R. or street: Rt. 2 City, state, zip code: Hoxie, KS 67701		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date _____ Well depth 234 ft. 11-10-78		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	130	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 1 1/2 in. PVC <input type="checkbox"/> Weight 31.75 lbs./ft. Dia. 2 3/4 in. to 234 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gauge No. .188		
Sand, Sandy Clay & Sandstone		130	160	10. Screen: Manufacturer's name Cook Type Wire Wrapped Dia. 16 Slot/gauze 100 Length 10' Set between 224 ft. and 234 ft. Perf. Brown 164 ft. and 224 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 30% #1; 70% #4x5		
Sandstone & Streaks of Clay		160	190	11. Static water level: _____ mo./day/yr. 144 ft. below land surface Date 11-17-78		
Fine Sand & Medium Gravel		190	200	12. Pumping level below land surfaces: 234 ft. after 2 hrs. pumping 838 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 838 g.p.m.		
Fine Sand & Medium Gravel		200	232	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Ochre & Shale		232	240	14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 5100 Direction East Type Farmstead Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name Floway Model number 10 DOH HP 70 Volts _____ Length of drop pipe 232 ft. capacity 575 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245 Business name License No. _____ Address Box 852 Colby, KS 67701 Signed E.D. Galton Date 12-6-78 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5