USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Sheridan	NW 1/4 NW 1/4 SW 1/4	27	T 7 S	R 30 E/W

2. Distance and direction from nearest town or city: 4 E 2 1/2 N
Street address of well location if in city: Menlo KS

3. Owner of well: Donald Kennedy Farm Inc.
R.R. or street:
City, state, zip code: Selden Ks. 67757

4. Locate with "X" in section below: Sketch map:

N — NW — NE — W — E — SW — SE — S — 1 Mile — 1 Mile

6. Bore hole dia. 28 in. Completion date 8-29-77
Well depth 279 ft.

7. __ Cable tool __ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored X Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Steel Height: Above or below
Threaded ___ Welded — Surface 12 in.
RMP ___ PVC ___ Weight ___ lbs./ft.
Dia 16 in. to 279 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 188

5. Type and color of material	From	To
Top Soil	0	125
Clay Fine Sand Sand Stone	125	135
— Sandy Clay —	135	145
Fine Sand	145	155
Fine Sand M Gravel Sandy Clay	155	165
— — S Stone	165	175
M Gravel Lime Color	175	185
Clay F Sand Sand Stone	185	205
Clay F Sand M Gravel. S. Stone	205	255
— — — Stuck	255	260
— — Hard	260	275
Ochre Shale	275	277

(Use a second sheet if needed)

10. Screen: Manufacturer's name W A Brown
Type Rieco Dia. 16
Slot/gauze 78 Length 80
Set between 199 ft. and 279 ft.
___ ft. and ___ ft.
Gravel pack? — Size range of material 4 x 5/8

11. Static water level: mo./day/yr.
103 ft. below land surface Date 8-29-77

12. Pumping level below land surfaces:
92 ft. after 3 hrs. pumping 800 g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 1200 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes — No Date ___

14. Well head completion:
__ Pitless adapter 12 Inches above grade

15. Well grouted? —
With: — Neat cement __ Bentonite __ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. ___ Direction ___ Type None
Well disinfected upon completion? ___ Yes ___ No

17. Pump: __ Not installed
Manufacturer's name Goulds
Model number 12 SHC HP 125 Volts ___
Length of drop pipe 270 ft. capacity 1200 g.p.m.
Type:
__ Submersible X Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

T 7 R 30 E/W Sec 27 1/4 1/4 1/4 NW NW SW

18. Elevation:
Topography:
__ Hill
__ Slope
X Upland
__ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Blue Jay Drilling Inc 214
Business name License No.
Address Box 503 Colby Ks
Signed Marilyn Rall Date 8-30-77
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023