


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 2	Township number T 7 S	Range number R 31 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: in Town				3. Owner of well: City of Rexford R.R. or street: City, state, zip code: Rexford, Kansas 67753		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 36 in. Completion date _____ Well depth 214 ft. 10-10-78		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Clay		0	45	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sand, gravel and clay		45	101	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 36 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 165 ft. depth Wall Thickness: inches or Dia. 16 in. to 124 ft. depth gage No. 375		
Sand and gravel		101	115	10. Screen: Manufacturer's name Johnson Type Galv. Steel Dia. 12" Slot/gauze 100 Length 30' Set between 165 ft. and 175 ft. 194 ft. and 214 ft. Gravel pack? yes Size range of material 50% 4x5/8		
Clay and sandstone		115	138	11. Static water level: 50% No. 91 ft. below land surface Date _____		
Clay, sandstone and sandmix		138	147	12. Pumping level below land surfaces: 118 ft. after 2 1/2 hrs. pumping 2 g.p.m. 127 ft. after 9 hrs. pumping 421 g.p.m. Estimated maximum yield 850 g.p.m.		
Fine to coarse sand		147	155	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sandstone, caliche and sand streaks		155	168	14. Well head completion: <input type="checkbox"/> Pitless adapter 36 Inches above grade		
Medium coarse sand, small gravel		168	173	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
Clay		173	190	16. Nearest source of possible contamination: ft. 600 Direction SW Type House Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Coarse sand and gravel		190	212	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number 6 10 LKM HP 50 Volts 460 Length of drop pipe 190 ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Ochre and shale		212	214	18. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. (245) Business name License No. 1100 S. Range, Colby, KS 67701 Address Signed Roy F. Linn Date 9-26-79 Authorized representative		
18. Elevation:		19. Remarks: BROCK 312'				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment