


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

South Well

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 32	Township number T 7 S R 31	Range number 31
2. Distance and direction from nearest town or city: From Colby' 12 1/2 East; 1 North Street address of well location if in city:				3. Owner of well: Kenneth Kenneth Schroeder R.R. or street: City, state, zip code: Oakley, Kansas		
4. Locate with "X" in section below: 				6. Bore hole dia. 30 in. Completion date 8-12-76 Well depth 224 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay				9. Casing: Material Steel Height: Above 0 xxxx Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 16 in. to 154 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7		
				10. Screen: Manufacturer's name W. A. Brown Type Bridge Dia. 16" Slot/gauze 10% Length 60' Set between 154 ft. and 214 ft. 10' Cook 214 ft. and 224 ft. Gravel pack <input checked="" type="checkbox"/> Size range of material 1/2 x 5/8		
Gravel				11. Static water level: 83 ft. below land surface Date 8-8-76		
Clay				12. Pumping level below land surfaces: 216 ft. after 2 hrs. pumping 2100 g.p.m. Estimated maximum yield 2100 g.p.m.		
Clay, Streaks of Gravel, Streaks of Sandstone				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Clay, Streaks of Sand Stone				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
Sand Stone Hard				15. Well grouted? <input checked="" type="checkbox"/> Clay With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> xxxx Depth: From 0 ft. to 10 ft.		
Coarse Sand, Streaks of Gravel				16. Nearest source of possible contamination: ft. 5500 Direction S Type House Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Med. Gravel				17. Pump: Manufacturer's name Floway Model number 056130 HP 150 Volts Length of drop pipe 210 ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852, Colby, KS 67701 Signed _____ Date _____ Authorized representative		
Med. Gravel						
Ochre & Shale						
BROCK 204						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5