USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.



WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

						Topeka, Kansas 66620	
1. Location of well:	County	Action	Market and the second	Section	number	Township number Range number	
	Thomas	NW 1/4 SW 1/4 NV	J 1/4		33	т 7 s R 32 x€/w	
				ner of well: Kenneth Poland			
Street address of well Tocation if in city:				or street: state, zip code: Gem, Kansas			
4 Locate with "X" in section below:  Sketch map:				***************************************		6. Bore hole dia. 30 in. Completion date 9-25. Well depth 248ft.	76
Well is 1300' N & 80' of SW Corner of ½				Е		7Cable toolRotaryDrivenDugHollow rodJettedBoredXReverse rotary	ıry
						8. Use:Domestic Public supply Industry X	
						Threaded Welded $X$ Surface $\frac{12}{188}$ in. RMP PVC Weight $\frac{188}{16}$ lbs./ft. Dia. $\frac{16}{16}$ in. to $\frac{15}{188}$ depth Wall Thickness; inches or	
ı⊸ l Mile → l					T	Dia. 16 in. to 15 & depth Wall Thickness; inches or Dia in. to ff. depth gage No#7	
5. Type and color of material				From	То	10. Screen: Manufacturer's name	<u>.</u>
Clay				0	40		
Gravel, Clay				40	60	Slot/gauze	
Clay, Streaks of & Gravel				60	100	Gravel pack? X Size range of material 4X5/8	₩30%#
Fine Sand, Clay				100	120	11. Static water level: mo./day/yr 106 ft. below land surface Date 9-26-76	
Coarse Sand, Med. Gravel, Clay				120	140	12. Pumping level below land surfaces: 172 ft. after 2 hrs. pumping 210Q.p.m.	
Med. Gravel, Streaks of Clay				140	160	ft. after hrs. pumping g.p.m.	
Fine Sand, Clay, Sand Stone Streaks				160	180	13. Water sample submitted: mo./day/yr	
Clay				180	184		
Coarse Sand, Med. Gravel				184	240	Pitless adapter 12 Inches above grade 15. Well grouted? X Clay	-
Med. Gravel				240		With:Negt cementBentoniteX CXNXXXe  Depth: FromOft. toOft.	
Ochre, Shale				243	248	16. Negrest source of possible contamination: ft. 1300 Direction 5 Type Farm	
15 KOCK 343'						Well disinfected upon completion? Yes X No	
AMERICA ALTERNATION ALTERNATION OF THE PARTIES PARTIES AND ALTERNATION OF THE PARTIES AND ALT			······································			17. Pump:   Not installed     Not installed	"   "
			·· <del>···································</del>	-		Length of drop pine243 ft capacity 1200 m	(X)m
						Submersible Turbine	15
(Use a second sheet if needed)						Jet Reciprocating Other	%   / / /
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report	]
Topography:						is true to the best of my knowledge and belief.	= 1
Hill Slope						Western Well & Pump 245  Business name Address Box 852, Colby, KS	12
X_ Upland						Signed Sally Berry Date 10-20	12/2
Valley						Authorized representative	1 \ 1 .