

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NW SE SE 1/4 NW 1/4	Section number 19	Township number T 7 S	Range number R 33 E
2. Distance and direction from nearest town or city: 2 miles N. 1/2 mile E. of Colby Street address of well location if in city:				3. Owner of well: Wayne A. Summers R.R. or street: RR. 1 Box 70 City, state, zip code: Colby Kansas 67701		
<input checked="" type="checkbox"/> Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 3/29/78 Well depth 215 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	34	9. Casing: Material plst Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 15 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.		
Sand Clay		34	38	Dia. 5 in. to 215 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 250		
Sand		38	47	10. Screen: Manufacturer's name J&L Type RMP Dia. 5" Slot/gauze .032 Length 20' Set between 195 ft. and 215 ft. ft. and <input type="checkbox"/> ft.		
Sand Clay		47	75	Gravel pack? yes Size range of material 1/8"		
Sand and Sand Rock Strips		75	144	11. Static water level: <input type="checkbox"/> mo./day/yr. 149 ft. below land surface Date <input type="checkbox"/>		
Sand Clay		144	152	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after n.a. hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
Sand		152	187	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>		
Sand and Sand Rock Strips		187	205	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 20 Inches above grade		
Sand Rock Hard		205	213	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 18 ft.		
Limer and Shale		213	215	16. Nearest source of possible contamination: ft. 140 Direction E Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
BROCK 213'				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bartell Drilling 139 Business name License No. Address Winona, Kansas 67764 Signed Wayne Bartell Date 7/7/79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5