


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: <u>Thomas</u>	Fraction: <u>NW 1/4 NE 1/4 NE 1/4</u>	Section number: <u>19</u>	Township number: <u>T 7 S</u>	Range number: <u>R 33 E</u>
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>152 North of Colby</u>			3. Owner of well: <u>Christopher Gerschner</u> R.R. or street: <u>Colby Kansas</u> City, state, zip code: <u>Colby Kansas</u>		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>4</u> in. Completion date <u>8-23-80</u> Well depth <u>224</u> ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>20</u> lbs./ft. Dia. <u>5</u> in. to <u>24</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>24</u> ft. depth gage No. <u>4-200</u>		
			10. Screen: Manufacturer's name <u>Jess L. Smith</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>1/8"</u> Length <u>8'</u> Set between <u>216</u> ft. and <u>224</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4-3/8</u>		
			11. Static water level: <u>143</u> ft. below land surface Date <u>8-23-80</u>		
			12. Pumping level below land surfaces: <u>143</u> ft. after <u>1</u> hrs. pumping <u>30</u> g.p.m. <u>117</u> ft. after <u>1</u> hrs. pumping <u>30</u> g.p.m. Estimated maximum yield <u>30</u> g.p.m.		
			13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>8-23-80</u>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>4</u> ft. to <u>14</u> ft.		
			16. Nearest source of possible contamination: ft. <u>200</u> Direction <u>South</u> Type <u>Shed</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Grundfos</u> Model number <u>13E-M</u> HP <u>1</u> Volts <u>220</u> Length of drop pipe <u>168</u> ft. capacity <u>13</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks: <u>Ohm 223-224</u>		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>B & B Drilling</u> <u>326</u> Business name License No. Address <u>Harvard St</u> Signed <u>Joseph Beckman</u> Date <u>8-15-80</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5