


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <u>Thomas</u>		Fraction: <u>NW 1/4 SE 1/4 SE 1/4</u>	Section number: <u>29</u>	Township number: <u>T 7 S</u>	Range number: <u>R 33 E/W</u>
2. Distance and direction from nearest town or city: <u>1 N - 1 E</u>			3. Owner of well: <u>Vincent Chad.</u>		
Street address of well location if in city: <u>Colby Ks</u>			R.R. or street: <u>R.R. Colby Ks.</u>		
City, state, zip code:					
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>6-1-76</u>	
				Well depth <u>192</u> ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug	
<u>Top soil</u>		<u>0</u>	<u>34</u>	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<u>sandy clay</u>		<u>34</u>	<u>59</u>	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
<u>Gravel</u>		<u>59</u>	<u>66</u>	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock	
<u>sandy clay & SS</u>		<u>66</u>	<u>93</u>	<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<u>Gravel</u>		<u>93</u>	<u>98</u>	9. Casing: Material <u>PVC</u> Height: Above or below	
<u>sandy clay & SS</u>		<u>98</u>	<u>104</u>	Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>System</u> in.	
<u>M gravel & gravel</u>		<u>104</u>	<u>123</u>	RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>System</u> lbs./ft.	
<u>sandy clay</u>		<u>123</u>	<u>126</u>	Dia. <u>5</u> in. to <u>192</u> ft. depth Wall Thickness: inches or	
<u>gravel & sandy clay</u>		<u>126</u>	<u>128</u>	Dia. <u>5</u> in. to <u>192</u> ft. depth gage No. <u>300</u>	
<u>sandy clay & SS</u>		<u>128</u>	<u>132</u>	10. Screen: Manufacturer's name <u>Joe Lowell</u>	
<u>fine sand & sandy clay</u>		<u>132</u>	<u>138</u>	Type <u>PVC</u> Dia. <u>5"</u>	
<u>sand stone</u>		<u>138</u>	<u>142</u>	Slot/gauze <u>1/32</u> Length <u>8'</u>	
<u>sandy clay & SS</u>		<u>142</u>	<u>163</u>	Set between <u>172</u> ft. and <u>180</u> ft.	
<u>gravel</u>		<u>163</u>	<u>180</u>	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1-1/2" 1/4"</u>	
<u>fine sand & sandy clay</u>		<u>180</u>	<u>190</u>	11. Static water level: <u>81</u> ft. below land surface Date <u>6-1-76</u>	
<u>Ochre</u>		<u>190</u>	<u>192</u>	12. Pumping level below land surfaces:	
				<u>81</u> ft. after <u>N/A</u> hrs. pumping <u>30</u> g.p.m.	
				<u>30</u> ft. after <u>30</u> hrs. pumping <u>30</u> g.p.m.	
				Estimated maximum yield <u>30</u> g.p.m.	
				13. Water sample submitted: <u>30</u> mo./day/yr.	
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>6-1-76</u>	
				14. Well head completion:	
				<input checked="" type="checkbox"/> Pitless adapter <u>10</u> inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/>	
				With: <u>Neat cement</u> <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete	
				Depth: From <u>0</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination:	
				ft. <u>300'</u> Direction <u>East</u> Type <u>Canal</u>	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump:	
				Not installed	
				Manufacturer's name <u>Grout</u>	
				Model number <u>2551</u> HP <u>2</u> Volt <u>230</u>	
				Length of drop pipe <u>153</u> ft. capacity <u>30</u> g.p.m.	
				Type:	
				<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography:		<u>BROCK 190'</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
<input type="checkbox"/> Hill				<u>Stuckhoff Sons</u> <u>298</u>	
<input checked="" type="checkbox"/> Slope				Business name License No.	
<input type="checkbox"/> Upland				Address <u>Stuckhoff Sons</u>	
<input type="checkbox"/> Valley				Signed <u>Stuckhoff</u> Date <u>7-26-76</u>	
				Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5