


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 17	Township number T 7 S	Range number R 34 E
X Distance and direction from nearest town or city: Thomas + 5 mi West of Colby			3. Owner of well: Mark-C Grain & Livestock R.R. or street: R.R. 1 City, state, zip code: Levant Ks. 67743			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 4/10/78 Well depth 481 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	42	9. Casing: Material plst Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 15 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 181 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No. 250		
Sand		42	46	10. Screen: Manufacturer's name J&L Type RMP Dia. 5 Slot/gauze .032 Length 20 ft. Set between 161 ft. and 181 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/8		
Sandy Clay & Sand Strips		46	61	11. Static water level: <input type="checkbox"/> mo./day/yr. 115 ft. below land surface Date 4/10/78		
Sand		61	65	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
Sand & Sand Rocks Strips		65	112	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Sand Rock Hard		112	127	14. Well head completion: no Pitless adapter 14 inches above grade		
Sand & Sand Rock Strips		127	154	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 18 ft.		
Sand		154	172	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction NA Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sandy Clay		172	174	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name not installed Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Shale		176	180	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bartell Drilling 139 Business name Wagon, Kansas License No. <input type="checkbox"/> Address <input type="checkbox"/> Signed James Bartell Date 8/30/78 Authorized representative		
BROCK 176						
18. Elevation:		19. Remarks: Windmill installed				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5