


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

North Well
WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 2	Township number T 7 S	Range number R 34 E/W
2. Distance and direction from nearest town or city: From Colby; 4 North; 2 West; 2 North; 1/2 East; 1/4 South Street address of well location if in city:				3. Owner of well: Cooper, Willard R.R. or street: City, state, zip code: Colby, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 7-14-76 Well depth 98 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Coarse Sand		0	17	9. Casing: Material Steel Height: Above or below X Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight .188 lbs./ft. Dia. 16 in. to 28 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7		
Coarse Sand & Gravel		17	34	10. Screen: Manufacturer's name Brown Type Regualr Dia. 16" Slot/gauze 10% Length 60' Set between 28 ft. and 88 ft. 10' Cook 88 ft. and 98 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 x 5/8 30% #1		
Clay		34	45	11. Static water level: <input type="checkbox"/> mo./day/yr. 26 ft. below land surface Date 7-16-76		
Cemented & Clay		45	53	12. Pumping level below land surfaces: 96 ft. after 2 hrs. pumping 421 g.p.m. 96 ft. after 2 hrs. pumping 421 g.p.m. Estimated maximum yield 421 g.p.m.		
Coarse Sand & Gravel		53	71	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Sand Stone Hard		71	72	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Coarse Sand & Gravel		72	78	15. Well grouted? <input checked="" type="checkbox"/> Clay With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> concrete Depth: From 0 ft. to 10 ft.		
Cement & Sandy Clay		78	82	16. Nearest source of possible contamination: ft. 1/2 M Direction W Type xxx Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Cement & Sand & Gravel		82	92	17. Pump: Manufacturer's name Floway Model number 056094 HP 40 Volts Length of drop pipe 90 ft. capacity <input type="checkbox"/> g.p.m. Type: 7 stage 10" DOL Bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sandy Clay & Clay		92	98	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business Name License No. Address Box 852 Colby, KS 67701 Signed Sally Berry Date 9-15-76 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		BROCK ?				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5