


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Township - Rovohl

1. Location of well:	County Thomas	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 14	Township number T 7 S	Range number R 34 E
2. Distance and direction from nearest town or city: 4 1/2 miles North; 1 1/2 miles West Street address of well location if in city:			3. Owner of well: Barnett, Morris R.R. or street: City, state, zip code: Colby, Kansas 67701		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date Well depth 237 ft. 1/26/76	
				7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary	
5. Type and color of material		From	To	8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other	
Clay		0	66	9. Casing: Material Steel Height: Above or below Threaded Welded X Surface 12 in. RMP PVC Weight lbs./ft.	
Coarse sand & gravel		66	78	Dia. 16 in. to 14 7/8 in. depth 147 ft. Wall thickness: inches or Dia. 16 in. to 14 7/8 in. depth 147 ft. gage No. 0.188	
Clay		78	84	10. Screen: Manufacturer's name Brown 10 Cook Type Regular Dia. 16" Slot/gauze 10% Length 80' Set between 147 ft. and 237 ft. 227 ft. and 237 ft.	
Coarse sand & gravel		84	90	Gravel pack? X Size range of material 5/8; 50% #1	
Sandy clay		90	94	11. Static water level: mo./day/yr. 140 ft. below land surface Date 1/28/76	
Coarse sand & gravel		94	97	12. Pumping level below land surfaces: 250 ft. after 4 hrs. pumping 556 g.p.m. 235 ft. after 2 hrs. pumping 672 g.p.m. Estimated maximum yield 556 672 g.p.m.	
Clay & sandy clay		97	108	13. Water sample submitted: mo./day/yr. Yes X No Date	
Coarse sand & gravel		108	120	14. Well head completion: Pitless adapter 12 inches above grade	
Clay		120	128	15. Well grouted? X With: Neat cement X Bentonite X Clay Depth: From 0 ft. to 10 ft.	
Medium to coarse sand		128	135	16. Nearest source of possible contamination: ft. 2600 Direction SE Type Farm Well disinfected upon completion? Yes X No	
Sandy clay		135	142	17. Pump: Not installed Manufacturer's name Floway Model number 7621 HP 100 2-13-76 Length of drop pipe 230 ft. capacity g.p.m. Type: 11 stage 10" DOH bowl Submersible X Turbine Jet Reciprocating Centrifugal Other	
Coarse sand & gravel & cemented streak		142	151	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Sandy clay & clay & sand streaks		151	171	Western Well and Pump 245 Business name License No. Address 60 Box 852 Colby, KS. Signed Sally Berg Date 3/27/76 Authorized representative	
Coarse sand & gravel		171	188		
Clay		188	192		
Coarse sand & gravel & layers of cement		192	213		
Clay		213	214		
Coarse sand & gravel		214	234		
Ochre & shale		234	250		
BROCK 234					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: Hill Slope X Upland Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5