

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Job #264-77-A-21-7-34

AAC

1. Location of well:	County Thomas	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 21	Township number T 7 S	Range number R 34 E/W
2. Distance and direction from nearest town or city: 2 3/4 N Street address of well location if in city:			3. Owner of well: Jeff Melton R.R. or street: City, state, zip code: Colby, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 30 in. Completion date 10-26-77 Well depth 223 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below XXXX Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 16 in. to 171 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7		
			10. Screen: Manufacturer's name Brown Type Bridge Dia. 16" Slot/gauze 10% Length 60' Set between 10' and 213 ft. and 223 ft. 10' Cook 28 and 223 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 5/8 30% #1		
			11. Static water level: 120 ft. below land surface Date 10-29-77 mo./day/yr.		
			12. Pumping level below land surfaces: 149 ft. after 2 hrs. pumping 650 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 838 g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 8000 Direction S Type House Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:			19. Remarks: BROCK 214		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. 67701 Address Box 852, Colby, KS Signed Ann Gerstner Date 12/23/77 Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5