


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Thomas</b>	Fraction <b>SE 1/4 SE 1/4 SE 1/4</b>	Section number <b>25</b>	Township number <b>7</b>	Range number <b>34</b>
2. Distance and direction from nearest town or city: <b>1/4 M N. and 1/4 M W. of Colby</b> Street address of well location if in city:			3. Owner of well: <b>Larry Schlick</b> R.R. or street: <b>265 S. Lincoln Box 211</b> City, state, zip code: <b>Colby, Kansas 67701</b>		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <b>8</b> in. Completion date <b>4/27/77</b> Well depth <b>215</b> ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <b>PLST</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>15</b> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <b>81</b> lbs./ft. Dia. <b>5</b> in. to <b>215</b> ft. depth Wall Thickness: inches or Dia. <b>5</b> in. to <b>215</b> ft. depth gage No. <b>1/4"</b>		
			10. Screen: Manufacturer's name <b>J and L</b> Type <b>RMP</b> Dia. <b>5 1/2</b> Slot/gauze <b>1/32"</b> Length <b>20'</b> Set between <b>175</b> ft. and <b>215</b> ft. ft. and <b>175</b> ft. Gravel pack? <b>yes</b> Size range of material <b>1/8"</b>		
			11. Static water level: <b>90</b> ft. below land surface Date <b>4/27/77</b>		
(Use a second sheet if needed)			12. Pumping level below land surfaces: ft. after <b>NA</b> hrs. pumping <b>NA</b> g.p.m. ft. after <b>NA</b> hrs. pumping <b>NA</b> g.p.m. Estimated maximum yield <b>NA</b> g.p.m.		
			13. Water sample submitted: <b>Yes</b> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <b>4/27/77</b>		
			14. Well head completion: <b>no</b> Pitless adapter <b>214</b> inches above grade		
			15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>24</b> ft. to <b>218</b> ft.		
			16. Nearest source of possible contamination: ft. <b>NA</b> Direction <b>none</b> Type <b>none</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
18. Elevation:  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <b>NA</b> Model number <b>NA</b> HP <b>NA</b> Volts <b>NA</b> Length of drop pipe <b>NA</b> ft. capacity <b>NA</b> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Bartell Drilling 139</b> Business name <b>Winona, Kansas 67764</b> License No. <b>NA</b> Address <b>NA</b> Signed <b>George Bartell</b> Date <b>4/27</b> Authorized representative		
			19. Remarks: <b>BROCK 211</b>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5