


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 36	Township number T 7 S R 34 E/W	Range number
2. Distance and direction from nearest town or city: 1 mile N 1/2 mile W of Colby, Ks. Street address of well location if in city: Lot 6 Block 2 El Chaparral				3. Owner of well: Michael Woofter R.R. or street: Box 726 City, state, zip code: Colby, Ks. 67701		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 7-31-80 Well depth 176 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay		0		33		9. Casing: Material styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 1.75 lbs./ft. Dia. 5 in. to 176 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .214
Fine Sand & Clay		33		42		10. Screen: Manufacturer's name Styrene Dia. 5 in. Type Slot Slot/gauze 156 Length 176 Set between 156 ft. and 176 ft. <input checked="" type="checkbox"/> Gravel pack? <input type="checkbox"/> Size range of material 1/4 in.
Clay		42		76		11. 85 static water level: 7-31-80 ft. below land surface Date
Medium Sand		76		86		12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
Clay		86		92		13. Water sample submitted: <input checked="" type="checkbox"/> Yes No Date
Fine to Med. Sand		92		94		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade
Clay		94		95		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
Med. Sand		95		115		16. Nearest source of possible contamination: Septic Tank ft. 150 Direction East Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes No
Clay		115		117		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Med. Sand		117		121		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. F & W Drilling 394A Business name Address Rt. 1 Hoxie, Ks. 67740 Signed _____ Date _____ Authorized representative
Clay		121		127		
Med. Sand		127		133		
Caliche		133		137		
Med. Sand		137		139		
Cemented Sand		139		153		
Med. Sand		153		176		
Caliche		176		177		
Clay		177		181		
Caliche		181		185		
Ochre		185		198		
Shale		198		210		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5