

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Thomas</u>		Fraction <u>NE 1/4 SE 1/4 NE 1/4</u>	Section number <u>36</u>	Township number <u>T 7 S</u>	Range number <u>R 34 E/W</u>
2. Distance and direction from nearest town or city: <u>1/2 N Colby Ks</u>			3. Owner of well: <u>LACK KRISS</u>		
Street address of well location if in city:			R.R. or street:		
			City, state, zip code: <u>Colby Ks.</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>9-11-76</u>	
				Well depth <u>190</u> ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>4'</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>5</u> in. to <u>190</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>200</u>	
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u>LESS LOWELL</u>
<u>top soil</u>			<u>0</u>	<u>34</u>	Type <u>PVC</u> Dia. <u>5</u>
<u>sandy clay</u>			<u>34</u>	<u>51</u>	Slot/gouge <u>1/32</u> Length <u>8'</u>
<u>gravel</u>			<u>51</u>	<u>85</u>	Set between <u>161</u> ft. and <u>169</u> ft.
<u>sandy clay & S.S.</u>			<u>85</u>	<u>92</u>	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8-1/4</u>
<u>gravel</u>			<u>92</u>	<u>101</u>	11. Static water level: <u>82</u> ft. below land surface Date <u>9-11-76</u>
<u>sandy clay</u>			<u>101</u>	<u>111</u>	12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.
<u>gravel</u>			<u>111</u>	<u>116</u>	Estimated maximum yield <u>40 +</u> g.p.m.
<u>sandy clay & S.S.</u>			<u>116</u>	<u>122</u>	13. Water sample submitted: <u> </u> mo./day/yr.
<u>fine sand & sandy clay</u>			<u>122</u>	<u>126</u>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>
<u>sandy clay & S.S.</u>			<u>126</u>	<u>138</u>	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade
<u>S.S.</u>			<u>138</u>	<u>145</u>	15. Well grouted? <input checked="" type="checkbox"/> With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete
<u>sandy clay & S.S.</u>			<u>145</u>	<u>150</u>	Depth: From <u>0</u> ft. to <u>10</u> ft.
<u>gravel</u>			<u>150</u>	<u>169</u>	16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>WEST</u> Type <u>DRAW</u>
<u>sandy clay</u>			<u>169</u>	<u>187</u>	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<u>Other</u>			<u>187</u>	<u>190</u>	17. Pump: <u> </u> Not installed
					Manufacturer's name <u>REDA</u>
					Model number <u>11035401</u> HP <u>3</u> Volts <u>230</u>
					Length of drop pipe <u>168</u> ft. capacity <u>30</u> g.p.m.
					Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:		19. Remarks: <u>BRUCK 187</u>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				<u>STRUCKHOFF SONS</u> <u>298</u> Business name License No. Address <u>GRINNELL Ks</u> Signed <u>[Signature]</u> Date <u>11-9-76</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5