Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number			
1. Location of well:	Thomas	SW 1/4 SW 1/4 SW 1/4		5		т 7 s	R	Jew		
1 C No 2 W				wner of well: Brenn, Stuart						
Street address of well location if in city:				y, state, zip code:		Colby, Kansas				
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. <u>30</u> in. Well depth <u>265</u> ft.	Completion	1 date	-30- 76	
						7Cable toolRotaryDrivenDugHollow radJettedBoredX Reverse rotary 8. Use:DomesticPublic supplyIndustryX IrrigationAir conditioningStockLawnOil field waterOther 9. Casing: MaterialSteel Height: Above or testow				
										ı→ 1 Mile → 1
5. Type and color of material				From	To	Diain. toft. depth gage No				
Clay				0	86	Brown				
Coarse Sand & Gravel Clay				120	120 129					
Coarse Sand & Gravel				129	146	Set between 155 ft. and 255 ft.				
Sand Stone Coarse SAnd & Gravel				146 147	147 152					
Clav				152	154	13 Static water level me /dev/vr				
Coarse Sand & Gravel				154 166	166 182					
Clay Red. to Coarse SANG & Graver&Clay Sandstone St. 100 102 103 104 105 105 106 107 1						12. Pumping level below land surfaces:				
Coarse SAnd & Gravel				193 200	200 202	ft. after hrs. pumpingg.p.m				
Coarse SAnd & Gravel				202 206	206	Estimated maximum yield				
Sandy Clay					219 234	Yes X No Date				
Coarse Sand & Gravel Rock - very hard				234 238	238 241	Pitless adapter Inches above grade				
Med. to Coarse Sand & Som Gravel - white Ochre & Shale				241 259	259 280	15. Well grouted? X Clay With: Neat cement X Bentonite X X XXXXX Depth: From O ft. to 10 ft.				
BROCK 259'						16. Nearest source of possible ft. 5000 Direction	contaminati	ion: pe <u>Fa</u>	ırm	
						Well disinfected upon comple		Yes _	X No	
						17. Pump: Manufacturer's name F10	wav	nstalled	",	
						Model number 05610 Length of drop pipe 250		00 _{Vol} _{by -} 550		
						Type: 12 stage 1	0" DOH	Bowl Turbine _	L	
(Use a second sheet if needed)						Jet Centrifugal	_	_ Recipro Other		
18. Elevation: 19. Kemarks: Topography: — Hill — Slopie						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name Addres Box 852, Colby, KS 67701 Signed Authorized representative				
Forward the white, blu	ve and pink copies to the Department	of Health and Environment				•	ا	Form WW	C-5	