

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.


LEVANT

WATER WELL RECORD  
KSA 82a-1201-1215

ABB

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Thomas</b>	Township name <b>Barrett</b>	Fraction <b>NW 1/4 of NE 1/4</b>	Section number <b>14</b>	Town number <b>7</b>	Range number <b>35</b>
Distance and direction from nearest town or city: <b>5 miles North of Levant, KS.</b>			3 Owner of well: <b>Wilbur Holloway Colby, Ks.</b>			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map: 4 Well depth: <b>237</b> ft. Date of completion <b>3-20-75</b> Well diameter <b>28</b> in.			
2 Type and color of material			5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
Clay & sand			7 Casing: Material <b>Steel</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>147</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth			
			8 Screen: <b>W. A. Brown</b> Manufacturer <b>bridge</b> Dia. <b>16"</b> Type <b>1/8</b> Length <b>2"</b> Slot/gauze <b>1/8</b> Length <b>2"</b> Set between <b>147</b> ft. and <b>227</b> ft. Fittings: <b>10'</b> of Cook -- <b>227-237</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/4 x 5/8</b>			
Fine to coarse sand & gravel			9 Static water level: <b>110</b> ft. below land surface Date <b>4-2-75</b>			
Sandy clay			10 Pumping level below land surfaces: <b>225</b> ft. after <b>2</b> hrs. pumping <b>830</b> g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield <b>830</b> g.p.m.			
Fine to coarse sand & gravel			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
Clay			12 Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade			
Fine to coarse sand & gravel			13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> & clay Depth: From <b>0</b> ft. to <b>10</b> ft.			
Clay & Cemented sand streaks			14 Nearest source of possible contamination: ft. <b>2</b> Direction <b>South</b> Type <b>Home</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Fine to coarse sand & gravel			15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Bryon Jackson</b> Model number HP <b>80</b> Volts Length of drop pipe <b>230</b> ft. capacity <b>830</b> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Cemented sand			16 Remarks: elevation <b>3269 (Topo)</b>			
Fine to coarse sand & gravel with cemented streak			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Western Well &amp; Pump Inc. 245</b> Business name License No. Address <b>P.O. Box 852, Colby, KS.</b> Signe <b>Roy F. Jensen</b> Date <b>May 27-75</b> Authorized representative			
Cemented sand & clay						
Cemented sand - very HARD						
Sandy clay						
Fine to coarse sand & gravel						
Shale <b>BROOK 230'</b>						
(use a second sheet if needed)						
16 Remarks: elevation <b>3269 (Topo)</b>						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						