

USE TYPEWRITER OR BALL  
POINT-PEN-PRESS FIRMLY,  
PRINT CLEARLY.

BREWSTER NE

WATER WELL RECORD  
KSA 82a-1201-1215

7 3 6 13  
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620


1 Location of well:	County <b>Thomas</b>	Township name <b>Barrett NE-NW-SE<math>\frac{1}{4}</math></b>	Fraction	Section number <b>13</b>	Town number <b>T 7 S</b>	Range number <b>R 36 W</b>
---------------------	-------------------------	--	----------	-----------------------------	-----------------------------	-------------------------------

Distance and direction from nearest town or city: **5 miles North and 5 miles East of Brewster, Kansas**  
Street address of well location if in city:

3 Owner of well:  
Address: **Bellamy Brothers  
Hastings, Nebraska**

Locate with "X" in section below:

Sketch map:



2	Type and color of material	From	To
	Clay with sand streaks	0	157
	Fine to coarse sand and gravel	157	169
	Sandy clay	169	180
	Fine to coarse sand and gravel, few clay lense	180	195
	Cemented sand (Hard)	195	205
	Sandy clay	205	213
	Fine to coarse sand and gravel with clay lense	213	229
	Cemented sand (Hard)	229	233
	Fine to coarse sand and gravel	233	238
	Cemented sand (Hard)	238	239
	Fine to coarse sand and gravel	239	270
	<b>BRICK ?</b>		
	(use a second sheet if needed)		

4 Well depth: **270** ft. Date of completion **11-25-74**  
Well diameter **23** in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug  
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry  
☒ Irrigation ☐ Air conditioning ☐ Commercial  
☐ Test well

7 Casing: Material **steel** Height: above/below  
Threaded ☐ Welded ☒ Surface **3** in.  
Diam. **16** in. to **270** ft. depth Gauge  
Weight **16** lbs./ft.  
Drive shoe? ☐ Yes ☒ No

8 Screen:  
Manufacturer **W. A. Brown**  
Type **bridge** Dia. **16"**  
Slot/gauze **1/8** Length **2"**  
Set between **180** ft. and **260** ft.  
Fittings: **10' of cook**  
Gravel pack ☒ Yes ☐ No Size range of material **1/8 x 3/8**

9 Static water level:  
**131** ft. below land surface Date **11-26-74**

10 Pumping level below land surfaces:  
**255** ft. after **2** hrs. pumping **800** g.p.m.  
\_\_\_\_ ft. after \_\_\_\_ hrs. pumping \_\_\_\_ g.p.m.  
Estimated maximum yield **800** g.p.m.

11 Water sample submitted:  
☐ Yes ☒ No Date \_\_\_\_

12 Well head completion:  
☐ Pitless adapter ☒ Inches above grade

13 Well grouted? ☐ Yes ☒ No  
☐ Neat cement ☐ Bentonite ☐ \_\_\_\_  
Depth: From \_\_\_\_ ft. to \_\_\_\_ ft.

14 Nearest source of possible contamination:  
ft. \_\_\_\_ Direction \_\_\_\_ Type \_\_\_\_  
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump: ☐ Not installed  
Manufacturer's name **Byron Jackson**  
Model number **81** HP **100** Volts **460**  
Length of drop pipe **263** ft. capacity **800** g.m.p.  
Type:  
☐ Submersible ☒ Turbine  
☐ Jet ☐ Reciprocating  
☐ Centrifugal ☐ Other

16 Remarks: elevation

Topography:

☐ Hill  
☐ Slope  
☒ Upland  
☐ Valley

17 Water well contractor's certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

**Western Well & Pump Inc.**

Business name License No.

Address **P.O. Box 852-Colby 245**

Signed **Roy F. Jackson** Date **1-8-75**  
Authorized representative