


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 32	Township number T 7 S	Range number R 36 W
2. Distance and direction from nearest town or city: Street address of well location if in city:		2 1/2 Miles North From Brewster 1 mile East		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date _____ Well depth 269 ft. 5/9/79		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
top Soil + Clay		0	115	9. Casing: Material _____ Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 2 lbs./ft.		
M-Sand + Sandy Clay		115	135	Dia. 16 in. to 269 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 180		
Sand Stone		135	155	10. Screen: Manufacturer's name _____ W.A. Brown Type hoses Dia. 16 Slot/gauze 7/16 Length 40 Set between _____ ft. and _____ ft. 169 ft. and 269 ft.		
		155	165	Gravel pack? <input checked="" type="checkbox"/> Size range of material 4x5/8		
		165	175	11. Static water level: _____ mo./day/yr. 124 ft. below land surface Date 5/9/79		
M-Sand - Sandy Clay		175	175	12. Pumping level below land surfaces: 269 ft. after 2 hrs. pumping 950 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 950 g.p.m.		
		175	205	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
		205	225	14. Well head completion: _____ Pitless adapter 12 inches above grade		
cemented Sand		225	235	15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
M-Sand		235	279	16. Nearest source of possible contamination: ft. _____ Direction _____ Type None Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
Oolite & Shale		279	280	17. Pump: _____ Not installed Manufacturer's name Howe Model number _____ HP _____ Volts _____ Length of drop pipe 260 ft. capacity 950 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Blue Jay Drilling Co. Inc. Business name _____ License No. _____ Address Box 502, Cully, Mo. Signed Auto Hall Date 5/9/79 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5