

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

AAE ACA


1 Location of well:	County <i>SHERMAN</i>	Township name <i>VILLE</i>	1/4 Fraction <i>SW 1/4 NE 1/4</i>	Section number <i>11</i>	Town number <i>7</i>	Range number <i>38</i>
---------------------	--------------------------	-------------------------------	--------------------------------------	-----------------------------	-------------------------	---------------------------

Distance and direction from nearest town or city:
EDSON 1 E 8 N
Street address of well location if in city:

3 Owner of well: *GARY COOPER*
Address: *GOODLAND KANSAS*

Locate with "X" in section below:
N

Sketch map:



4 Well depth: *310* ft. Date of completion *1-7-75*
Well diameter *26* in.

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

6 Use: Domestic Public supply Industry
 Irrigation Air conditioning Commercial
 Test well

7 Casing: Material *Steel* Height: above/below
Threaded Welded Surface *12* in.
Diam. Weight *33* lbs./ft. *L*
16 in. to *200* ft. depth Drive shoe? Yes No
— in. to — ft. depth!

2	Type and color of material	From	To
	<i>FINE SAND, M GRAVEL, SANDSTONE</i>	<i>137</i>	<i>160</i>
	<i>M GRAVEL</i>	<i>160</i>	<i>166</i>
	<i>SANDY CLAY</i>	<i>166</i>	<i>178</i>
	<i>M GRAVEL, SANDY CLAY, SANDSTONE</i>	<i>178</i>	<i>206</i>
	<i>GRAVEL, SANDSTONE</i>	<i>206</i>	<i>217</i>
	<i>SANDY CLAY, SANDSTONE</i>	<i>217</i>	<i>223</i>
	<i>FINE SAND, SANDY CLAY SANDSTONE</i>	<i>223</i>	<i>252</i>
	<i>FINE SAND, GRAVEL, SANDSTONE</i>	<i>252</i>	<i>281</i>
	<i>FINE SAND, M GRAVEL, SANDY CLAY</i>	<i>281</i>	<i>290</i>
	<i>FINE SAND, M GRAVEL</i>	<i>290</i>	<i>300</i>
	<i>M GRAVEL, Clay, Shale</i>	<i>300</i>	<i>310</i>
	<i>5000 309</i>		

8 Screen:
Manufacturer *W.A. BROWN*
Type *LUYER* Dia. *16*
Slot/gauze *18-7* Length *110*
Set between *200* ft. and *310* ft.
Fittings:
Gravel pack Yes No Size range of material *4/8 5/8*

9 Static water level:
145 ft. below land surface Date *1-9-75*

10 Pumping level below land surfaces:
195 ft. after *7* hrs. pumping *800* g.p.m.
280 ft. after *3* hrs. pumping *112* g.p.m.
Estimated maximum yield *1125* g.p.m.

11 Water sample submitted:
 Yes No Date _____

12 Well head completion:
 Pitless adapter Inches above grade

13 Well grouted? Yes No
 Neat cement Bentonite
Depth: From *0* ft. to *10* ft.

14 Nearest source of possible contamination:
ft. _____ Direction _____ Type *None*
Well disinfected upon completion? Yes No

15 Pump: Not installed
Manufacturer's name *WESTERN LAND PUMPS*
Model number *6M* HP *90* Volts _____
Length of drop pipe *290* ft. capacity *600* g.m.p.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

16 Remarks: elevation *3578 (TOP)*
3520

Topography:
 Hill
 Slope
 Upland
 Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
A & H Pulling Co. Inc. 166
Business name License No. _____
Address *Goodland Kan.*
Signed *Bill Chappell* Date *2-4-75*
Authorized representative