

LOCATION OF WATER WELL: County: Mitchell Fraction: SE 1/4 SE 1/4 SW 1/4 Section Number: 10 Township Number: T 7 S Range Number: R 7 EW

Distance and direction from nearest town or city? Beloit limits Street address of well if located within city? 919 E. Main

WATER WELL OWNER: Paul Robinson Board of Agriculture, Division of Water Resources
 R#, St. Address, Box #: 919 E. Main Application Number:
 City, State, ZIP Code: Beloit, Ks.

DEPTH OF COMPLETED WELL: 36 ft. Bore Hole Diameter: 8 in. to 36 ft., and in. to ft.

Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 7 Lawn and garden only 10 Observation well
 Well's static water level: 18 ft. below land surface measured on 4 month 24 day 80 year
 Pump Test Data: Well water was 26 ft. after 1 hours pumping 20 gpm
 Test Yield: Well water was ft. after hours pumping gpm

TYPE OF BLANK CASING USED:
 1 Steel 2 PVC 3 RMP (SR) 4 ABS 5 Wrought iron 6 Asbestos-Cement 7 Fiberglass 8 Concrete tile 9 Other (specify below) Casing Joints: Glued Clamped
 10 Other (specify below) Welded
 Threaded
 Blank casing dia: 5 in. to 36 ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface: 24 in., weight 200 lbs./ft. Wall thickness or gauge No. 200

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 2 Brass 3 Stainless steel 4 Galvanized steel 5 Fiberglass 6 Concrete tile 7 PVC 8 RMP (SR) 9 ABS 10 Asbestos-cement 11 Other (specify)
 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 2 Louvered shutter 3 Mill slot 4 Key punched 5 Gauzed wrapped 6 Wire wrapped 7 Torch cut 8 Saw cut 9 Drilled holes 10 Other (specify)
 11 None (open hole)
 Screen-Perforation Dia: 5 in. to ft., Dia in. to ft., Dia in. to ft.
 Screen-Perforated Intervals: From 26 ft. to 36 ft., From ft. to ft., From ft. to ft.
 Gravel Pack Intervals: From 10 ft. to 36 ft., From ft. to ft., From ft. to ft.

GROUT MATERIAL: 0 Neat cement 1 Cement grout 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 0 ft. to 10 ft., From ft. to ft., From ft. to ft.

What is the nearest source of possible contamination:
 1 Septic tank 2 Sewer lines 3 Lateral lines 4 Cess pool 5 Seepage pit 6 Pit privy 7 Sewage lagoon 8 Feed yard 9 Livestock pens 10 Fuel storage 11 Fertilizer storage 12 Insecticide storage 13 Watertight sewer lines 14 Abandoned water well 15 Oil well/Gas well 16 Other (specify below)
 Direction from well: South How many feet: 70 ft? Water Well Disinfected? Yes No
 Has a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample submitted month day year: Pump Installed? Yes No
 Yes: Pump Manufacturer's name Model No. HP Volts
 Depth of Pump Intake ft. Pumps Capacity rated at gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on April month 24 day 80 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 328
 This Water Well Record was completed on April month 26 day 80 year under the business name of Pestinger Drilling Co by (signature) David C Pestinger

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	6	Top Soil			
	6	18	Clay - L grey			
	18	32	Sand - V fine L - Brown			
	32	36	Creek gravel Cream & light grey			
	36	?	Dark grey Clay			

ELEVATION:
 Depth(s) Groundwater Encountered 1. 18 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.