


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Rooks	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 34	Township number T 8 S R	Range number 19 W #W
2. Distance and direction from nearest town or city: Street address of well location if in city: 5 miles North of Zurich			3. Owner of well: Richard Cerrow R.R. or street: R.R. #1 City, state, zip code: Plainville, Kansas 67663		
4. Locate with "X" in section below: 			Sketch map: Well is about 150' East of road on level ground		
5. Type and color of material			From	To	6. Bore hole dia. 10 in. Completion date 5-5-78 Well depth 45 ft.
Top soil sandy clay			0	14	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Limestone and yellow clay			14	24	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sand and white gravel			24	28	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 214
Black Shale			28	45	10. Screen: Manufacturer's name Jet Streamer Type slots Dia. 5" Slot/gauze 1/16" Length 10' Set between 15 ft. and 25 ft. Gravel pack? yes Size range of material 1/8" to 1/4"
					11. Static water level: 19 ft. below land surface Date 5/5/78 mo./day/yr.
					12. Pumping level below land surfaces: 22 ft. after 1 hrs. pumping 12 g.p.m. 22 ft. after 3 hrs. pumping 10 g.p.m. Estimated maximum yield 25 g.p.m.
					13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 15 ft.
					16. Nearest source of possible contamination: ft. 1300 Direction W Type oil well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Well is to be used for stock and house Owner will put in pitless adapter and concrete curb Knows it is State requirement		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rush Water Well Service 310 Business name License No. Address Natoma, Kansas 67651 Signed Oscar Rudy Date 5/7/78 Authorized representative		

T-8
 R-19
 Sec 34
 1/4 1/4 1/4
 SWSWSW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5