

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Cloud	Fraction NE 1/4 SW 1/4 NW 1/4	Section number 32	Township number T 8 S R	Range number 2 E (W)	
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Otto Braun R.R. street: #2 City, state, zip code: Miltonvale, Mo 67466				
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 20 in. Completion date Well depth 224 ft. 7-6-76				
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
5. Type and color of material			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Low <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material AL Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 24 lbs./ft. Dia. 12 in. to 224 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 34				
			10. Screen: Manufacturer's name Johnson Concrete Type transite Dia. 12 Slot/gauge 1/8 Length 42 Set between 182 ft. and 224 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 1/8-1/4				
			11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface Date 7-6-76				
			12. Pumping level below land surfaces: 70 ft. after 1 hrs. pumping 1100 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1500 g.p.m.				
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>				
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade				
			15. Well grouted? <input checked="" type="checkbox"/> YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				
			16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WLR Model number 8M HP 100 Volts <input type="checkbox"/> Length of drop pipe 210 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dev Cox & Sons, Inc 258 Business name License No. Address Clifton, Kansas Signed Thomas Cox Date 7-6-76 Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T-8
 R-2
 W-1
 Sec-32
 1/4 1/4 1/4
 WESUM