

Access

BOGUE

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Graham		Fraction BBA NE 1/4 NW 1/4 NW 1/4	Section number 15	Township number T 8 S R 21 E 10	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 1/2 E Bogue, Ks.			3. Owner of well: Larry Gosselin R.R. or street: City, state, zip code: Damar, Ks. 67632		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 30 in. Completion date 4/24/80 Well depth 72 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Top Soil		0	23	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gravel		23	72	9. Casing: Material _____ Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 12 in. to 72 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gauge No. 188	
				10. Screen: Manufacturer's name _____ W.A. Brown Type 100-2 Dia. 12 Slot/gauze _____ Length 30 Set between 52 ft. and 72 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4-5/8	
				11. Static water level: _____ mo./day/yr. 32 ft. below land surface Date 4/24/80	
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. 72 ft. after 3 hrs. pumping 650 g.p.m. Estimated maximum yield 650 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.	
				16. Nearest source of possible contamination: ft. _____ direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: 2020 72 1948		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Blue Jay Drilling 914 Business name License No. Address Box 503 Colby, Ks. Signed John Hall Date 4/27/80 Authorized representative		

T-8
R-210
E-15
Sec-NE NW NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5