

HILL CITY'S

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

B3A

1. Location of well: County Graham Co. Fraction NE 1/4 NW 1/4 NW 1/4 Section number 18 Township number T 8 S R 22 E/W Range number

2. Distance and direction from nearest town or city: 1 mile east of Hill City, Limits, ON HIGHWAY #24. Street address of well location if in city: #24. 3. Owner of well: Walter E. Maier R.R. or street: Hill City, Mo. 67642 City, state, zip code:

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 9 in. Completion date 5/4/78  
Well depth 91 ft.

7. Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material PLSTX Height: Above or below  
Threaded  Welded 91 Surface 24 in.  
RMP  PVC  Weight        lbs./ft.  
Dia. 5 in. to 91 ft. depth Wall Thickness: inches or  
Dia.        in. to        ft. depth gage No. 250

10. Screen: Manufacturer's name         
Type plastic Dia. 5"  
Slot/gauze 1/16 Length 10'  
Set between 81 ft. and 91 ft.  
ft. and        ft.  
Gravel pack?  Yes Size range of material 1/4" - 3/8"

11. Static water level: 53 ft. below land surface Date 5/4/78 mo./day/yr.

12. Pumping level below land surfaces: NOT PUMPED  
       ft. after        hrs. pumping        g.p.m.  
       ft. after        hrs. pumping        g.p.m.  
Estimated maximum yield        g.p.m.

13. Water sample submitted:        mo./day/yr.  
Yes  No  Date       

14. Well head completion: NOT done  
 Pitless adapter        Inches above grade

15. Well grouted?  Yes  
With:  Neat cement  Bentonite  Concrete  
Depth: From 7 ft. to 17 ft.

16. Nearest source of possible contamination: HOUSE  
ft. 150 Direction WEST Type SEPTIC  
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name         
Model number        HP        Volts         
Length of drop pipe        ft. capacity        g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

18. Elevation: 2166  
(Use a second sheet if needed)

19. Remarks: Customer to run Cement slab to be installed @ ground level.

20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
D. E. L. DRILLING CO  
Business name: 67642 License No.         
Address HILL CITY, MO. 303  
Signed Walter E. Maier Date 5/15/78  
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

8-220-18 NEW