

HILL CITY 5

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

BAA

1. Location of well:		County GRAHAM	Fraction NW 1/4 NE 1/4 NW 1/4	Section number 13	Township number T 8 S	Range number R 23 W
2. Distance and direction from nearest town or city: Hill City, KS			3. Owner of well: DELBERT GARRISON			
Street address of well location if in city: DN Highway 24			R.R. or street: HWY. 24 EAST			
			City, state, zip code: HILL CITY, KS, 67642			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 in. Completion date 4/11/78 Well depth 63 ft.	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PLST Height: Above or below Threaded <input type="checkbox"/> Welded 9ld Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 63 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .250		
				10. Screen: Manufacturer's name Jess E Howell Type PLASTIC Dia. 5" Slot/gauze 1/16 Length 10' Set between 53 ft. and 63 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/4 - 5/8"		
				11. Static water level: _____ mo./day/yr. 39 ft. below land surface Date 4/11/78		
				12. Pumping level below land surfaces: NOT PUMPED _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: NOT DONE <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 20 ft. to 20 ft.		
				16. Nearest source of possible contamination: Houses ft. 150' Direction E+N Type HOMES Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		(Use a second sheet if needed) Concrete slab to be installed by customer at surface of ground.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Box 368, Hill City, KS, 67642 Business name: _____ License No. _____ Address D. E. L. Drilling 303 Signed Robert J. ... Date _____ Authorized representative		

S-230 13N E NEW