

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CDIS

1. Location of well:		County Graham	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 35	Township number T 8 S	Range number R 23 E/W
2. Distance and direction from nearest town or city: W Hill City, Kan. 4 mi. S. 2 1/2				3. Owner of well: GRAY GENE R.R. or street: R.R. City, state, zip code: Hill City, Kan.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 8-9-76 Well depth 54 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Plastic Height: Above or below Threaded Welded Surface 24 in. RMP PVC Weight 3 lbs./ft. Dia. 5 in. to 54 ft. depth Wall Thickness: inches or Dia. 5 in. to 54 ft. depth gage No. 200		
				10. Screen: Manufacturer's name JOSSLOWELL Type Plastic Dia. 5' Slot/gauze 16' Length 10' Set between 44 ft. and 54 ft. ft. and 54 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material #20-56		
				11. Static water level: 33 ft. below land surface Date 8-9-76 mo./day/yr.		
				12. Pumping level below land surface: 33 ft. after 10 hrs. pumping 18 g.p.m. 18' set thick 18 g.p.m. Estimated maximum yield 18 g.p.m.		
				13. Water sample submitted: NOT in Og mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 6 ft. to 16 ft.		
				16. Nearest source of possible contamination: cess pool ft. 100 Direction E Type cess pool Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		2210 2159		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ALL DRILLING CO 303 Business name License No. Address Hill City, Kan. Signed ALLAN J. JONES Date 8-28-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5